

This list is updated as of 6/30/2018. All fixtures that had exceedance levels have been remediated.

The corrective action to remediate lead in drinking water taken by school districts and funded with SFB Building Renewal Grant monies may exceed the ADEQ recommended corrective action due to the requirements established in A.R.S. § 15-2011, A.R.S. § 15-2011 version 2, and A.A.C. Title 7, Chapter 6, Article 2 (Minimum School Facility Guidelines).

Total Number Of Schools:	160
Schools Complete:	160
Schools In Progress:	0
Percent Complete:	100.00%

Sr. No.	School District	School	Confirmation Testing W/Exceedances	Total Number of Buildings under Remediation in PCA Phase	Building Numbers/Names	Scope of Work	Third Round Testing (Y/N)	Fixtures with Defences Detected	Comments	Corrective Action	Post Corrective Action Results (High/Low)	4th Round Testing - Current Status	Project Complete
1	Agua Fria Union High School District	Millennium High School	Confirmation Test Results >15 PPB	1	Bldg C/1003	1 Sink with Backflow	Y	Bldg C upper sink	Confirmation Test Results>15 PPB	Bldg C Upper Sink (Inhouse)	Low PCA Results		X
2	Alhambra Elementary District	Andalucia Middle School	Confirmation Test Results >15 PPB	2	Bldg 1006; 1014	Done. 11 Sinks.	Y	Bldg E and L with 7 and 4 Sinks Respectively.	Bldg E = 1014 ; Bldg L = 1006. BRG To Be Approved Shortly	Pursuing BRG Quotes			X
3	Alhambra Elementary District	Barcelona Middle School	Confirmation Test Results >15 PPB	1	Bldg 1004	Done. 18 sinks.	Y	Bldg 1004 - 18 sinks	BRG was approved 3/1/17 for \$10,000. Dominion has testing costs (\$3,000), 2 ftns & 2 fixtures installed.	Confirmation Testing >15ppb for 16 water sources New BRG Approved. Need 4th round testing. Old BRG value is \$10,000 and never invoiced by district. District needs to invoice for items completed.			X
4	Alhambra Elementary District	Family Resource Center (Formerly Called Cordova PS)	Confirmation Test Results >15 PPB	1	TBC	Done. 1 Sink.	Y	Sink in Teachers Lounge-ID1	Confirmation tested @1500ppb	Pursuing BRG Quotes			X
5	Alhambra Elementary District	Cordova School (Formerly called Cordova Middle School)	Confirmation Test Results >15 PPB	2	Bldg 1001; 1007	Done. 10 Sinks	Y	Bldg 1001 & 1007 Sinks	Need BRG to correct fixtures. Waiting on corrective actions	Pursuing BRG Quotes			X
6	Alhambra Elementary District	Granada East School	Confirmation Test Results >15 PPB			Done. 7 Sinks.	Y	Boys Restroom Sinks (5) and Girls Restroom Sink (2) in the Multi-Purpose Room (MPR)	BRG was approved 3/1/17. Dominion has testing costs & 2 compartment sink fixtures installed. 3 gang sink was removed.	3rd round testing >15ppb for 2 water sources. Need 4th round testing and updated quotes from Matt on existing BRG. BRG current value is \$10,000 and never invoiced by district. District needs to invoice for items completed. More corrective action is required.			X
7	Alhambra Elementary District	Sevilla West	Confirmation Test Results >15 PPB			Fixtures in the Excluded Space. ADEQ Considering them as Non-Drinking Water Sources. No Potential BRG. District advised to do it in inhouse!	N	Little League Shack-Girls excluded space! Do not use for drinking water per ADEQ. No other drinking sources in Bldg.	Done	Done Inhouse! No BRG needed! Signage to be issued! To be Confirmed!	Signages Posted		X
8	Alhambra Elementary District	Westwood Primary School	Confirmation Test Results >15 PPB			Done. 4 Sinks.	Y	Bldg 1007 room 609(4) Sinks	Need BRG to correct fixtures				X
9	Alpine Elementary District	Alpine Elementary School	Confirmation Test Results >15 PPB				Y	Bldg W sinks	Do not use for drinking water per ADEQ. No other drinking sources in Bldg.	Typically, no hardware corrective action required. Perminant signage was installed. Kitchen faucets (3) were replaced.		Low 4th Round Test Results	X
10	Amphitheater Unified District	Marion Donaldson ES	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain.	Y	Bldg A sink/drinkingftn	Initial Test@20ppb		Low PCA Results		X
11	Apache Junction Unified District	Apache Junction High School	Confirmation Test Results >15 PPB			Done. 2 Sinks.	Y	Bldg W sinks(2)		Sinks corrected inhouse and up for PCA testing!	Low PCA Results		X
12	Avondale Elementary School District	Avondale Middle School	Complete			Done. 1 Sink.	N		No need for 3rd round tests	Signages Posted! Thus, Project Closeout!	Signages Posted		X
13	Bisbee USD	Bisbee HS	Complete			capped off water source & moved fixture to concession stand which was tested <15ppb.	N	Gym ice room	Do not use for drinking water per ADEQ. No other drinking sources in Bldg.		Fixture Capped Off		X
14	Cartwright Elementary District	Byron A Barry Elementary School	Confirmation Test Results >15 PPB			Done. 5 Sinks and 2 Drinking Fountains	Y	Bldgs 1001,1004,1007	Bldg 1001 Sinks (5), Bldg 1004 and 1007 have 1 Drinking Fountain each.				X
15	Cartwright Elementary District	Cartwright Preschool & Gifted Center	Confirmation Test Results >15 PPB			Done. 14 Sinks	Y	1 left sink	Bldg 1009 Sinks (10), Bldg 1002 and 1003 Sink (1) each, Bldg 1005 Sinks (2)				X
16	Cartwright Elementary District	Estrella Middle School	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain and 1 Left Sink	Y	Bldg 1002 room 49 sink & boys PE rm					X
17	Cartwright Elementary District	Flor Del Sol School	Confirmation Test Results >15 PPB			Done. 1 Tap and 1 Sink Tap.	Y	Bldg A Kitchen & Bldg B Restroom					X

18	Cartwright Elementary District	Heatherbrae ES	Complete			Putting up a Signage as a part of Permanent Fix!	N	Bldg's 1008-1012 sink taps - NON-DRINKING WATER SOURCE	Samples taken from a Non-Drinking Water Source		Corrective Actions Ongoing!		X
19	Cartwright Elementary District	Palm Lane School	Confirmation Test Results >15 PPB			Done. 3 Sinks and 1 Drinking Station	Y	Bldg 1004 & 1002 sinks(6)&ftn	confirm. Tests>15ppb				X
20	Cartwright Elementary District	Peralta Elementary School	Confirmation Test Results >15 PPB			Done. 4 Sink Taps.	Y	Bldg's 1008-1010	Per ADEQ, the fixtures aren't a drinking water sources. Need Confirmation from the Superintendent regarding his/her decision.				X
21	Cartwright Elementary District	Starlight Park	Confirmation Test Results >15 PPB				Y	Bldg's 1002 & 1003 sinks(7)&bubblers(3)	Sampling to be done soon				X
22	Cartwright Elementary District	Tomahawk ES	Confirmation Test Results >15 PPB			Done. 3 Sinks and 2 Bubblers.	Y	Bldgs 1001, 1004, 1005 & 1007 sinks & bubblers	Sampling to be done soon				X
23	Casa Grande Elementary District	Palo Verde School	Confirmation Test Results >15 PPB			Done. 2 dual unit drinking fountains. 2 water heaters. 1 single unit drinking fountain and 1 classroom sink bubbler.	Y	B Wing classroom B3	Corrective Actions Completed! School ready for 3rd Round Testing to be scheduled by ADEQ	2 dual unit drinking fountains. 2 water heaters. 1 single unit drinking fountain and 1 classroom sink bubbler.	Low PCA Results		X
24	Cave Creek Unified School District	Black Mountain ES	Confirmation Test Results >15 PPB			Done. 1 sink.	Y	Bldg 400 Sinks (2)	2 samples > 15 PPB @ 97.1 & 20.5	BRG Approved! Waiting for Corrective Actions to get completed! Follow-Up! PCA Testing to be scheduled with Legend afterwards!	Low PCA Results		X
25	Cave Creek Unified School District	Desert Arroyo MS	Confirmation Test Results >15 PPB			Done. (7) 400 Sinks and (9) 600 sinks.	Y	Bldgs 400 sinks(7)& 600 sinks (9)	confirm. Tests>15ppb	BRG Approved! Waiting for Corrective Actions to get completed! Follow-Up! PCA Testing to be scheduled with Legend afterwards!	Low PCA Results		X
26	Chinle UD	Chinle ES	Confirmation Test Results >15 PPB			Done. 1 Bubbler.	Y	CES Main Bldg bubbler in classroom 228	confirm. Tests>15ppb	1 Bubbler. Conducted Inhouse!	High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
27	Clarkdale-Jerome Elementary District	Clarkdale-Jerome Elementary School	Confirmation Test Results >15 PPB			A Pod Drinking Fountain has been Capped Off. B Pod Drinking Fountain has been removed and replaced!	Y	Bldg B work room DF	initial test@43ppb		Low PCA Results		X
28	Coolidge Unified District	West Elementary School	Confirmation Test Results >15 PPB			Done. 3 Sinks.	Y	3 Sinks		Signage!	Signages Posted		X
29	Creighton Elementary District	Biltmore Preparatory Academy	Confirmation Test Results >15 PPB			Done.	Y	Corrective Actions Ongoing! Jim to sign the Change order to give us an update for the School District!	Drinking fountains west side of multi purpose room; Snack bar in multi purpose room food prep sink faucet		High PCA Results		X
30	Creighton Elementary District	Creighton Elementary School	Confirmation Test Results >15 PPB			Done.	Y	Corrective Actions Ongoing! Jim to sign the Change order to give us an update for the School District!	Drinking fountains on west side of the 400 wing, south side of the library, east side of the 400 wing; Faucet in library office sink, 802 classroom sink, girls restroom 800 building, computer lab room 203, Room 210 faucet and bubbler in sink; Faucet and bubbler in room 215		High PCA Results		X
31	Creighton Elementary District	Larry C Kennedy School	Confirmation Test Results >15 PPB			Done.	Y	Corrective Actions Ongoing! Jim to sign the Change order to give us an update for the School District!	Drinking fountains on the south side of the 600 wing		Low PCA Results		X
32	Creighton Elementary District	Loma Linda Elementary School	Confirmation Test Results >15 PPB			Fixtures Replaced. Completed	Y	Room 811 bubbler and faucet in sink, Room 302 sink, Room 106 sink and bubbler	Jim to sign the Change order to give us an update for the School District		Low PCA Results		X
33	Deer Valley Unified District	Mountain Ridge High School	Confirmation Test Results >15 PPB			Contacted. 1 Sink.	Y	1 Sink in Snack Bar. ADEQ and Larry to give update on the type of fixture.	Confirmation Test @ 44		Low PCA Results		X
34	Flagstaff USD	W F Killip ES	Confirmation Test Results >15 PPB				Y				Low PCA Results		X
35	Flowing Wells Unified District	Flowing Wells High School	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain, 1 Sink and 1 Bubbler.	Y	ROTC classroom ftn, tap, bubbler	BRG Approved!	Done.	Low PCA Results		X
36	Fredonia-Moccasin Unified District	Fredonia High School				Done. Confirmation Test shows 2 Tap/Sinks and 1 Red Hose Nozzle in the Football Field. (NDWS)	Y	Football Ticket Booth Men's and Women's Restroom Tap; Additional red hose nozzle in the field as well	Confirm. Tests@51&27ppb. Deficiencies to be corrected inhouse before the football season starts.		Low PCA Results		X
37	Ganado Unified School District	Ganado High School	Confirmation Test Results >15 PPB				Y	Lab Classroom #B126 sink #10 and Lab Classroom #B127 sinks #1, #2, #4 & #7 tested >15ppb in Investigation Sampling for 19 Sinks	Signages Posted in both the Labs containing Lab Sinks. District to install a new Drinking Fountain in the Hallway.	School District advised to put up signs in front of these sinks stating that they are not a Drinking Water Sources. A separate Drinking Fountain is advised to be installed in the Hallway for Students and Lab Instructor to drink water.	PCA Testing Investigation Results Received	Low fourth round results	X
38	Gila Bend Unified District	Gila Bend Elementary School	Confirmation Test Results >15 PPB			Done. 1 DF.	Y	Cafeteria fountain			Low PCA Results		X
39	Gilbert Unified District	Canyon Valley School (formerly GPS Learning Center and ACE)	Confirmation Test Results >15 PPB				N		Source removed in Paint shop	Capped Off, thus project closeout to be done.	Capped Off		X

40	Glendale Elementary District	Challenger Middle School	Confirmation Test Results >15 PPB				Y		All fixtures are non-drinking water sources	Signages Posted!	Signages Posted		X
41	Glendale Elementary District	Glendale Landmark Middle School	Confirmation Test Results >15 PPB				Y		All fixtures are non-drinking water sources	Signages Posted!	Signages Posted		X
42	Glendale Union High School District	Apollo High School	Confirmation Test Results >15 PPB			Done.	Y	Bldg 14A&13 taps&fountains(5)	4 drinking fountains (Elkay) were replaced by school	4 drinking fountains (Elkay) were replaced. Follow up sampling to come	High PCA Results	4th round in progress	X
43	Glendale Union High School District	Cortez High School	Confirmation Test Results >15 PPB			Done.	Y	Bldg 300 taps(19)	Confirm. tests>15ppb		Signages Posted		X
44	Glendale Union High School District	Glendale High School	Confirmation Test Results >15 PPB			Done.	Y	Bldg 280 taps(16)	Confirm. tests>15ppb		Signages Posted		X
45	Glendale Union High School District	Washington High School	Confirmation Test Results >15 PPB			Done.	Y	Bldg 800 tap, 100s ftn, 400s tap	Confirm. Tests>15ppb		Low PCA Results		X
46	Hayden-Winkelman USD	Hayden High School	Confirmation Test Results >15 PPB			Done	Y	Bldg 1002, 1003, 1006	4 fixtures (3 drinking fountain and 1 sink)	Plumbing corrective actions	Low PCA Results		X
47	Hayden-Winkelman USD	Leonor Hambley MS	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain and 1 Sink.	Y	1 drinking fountain and 1 classroom sink	Confirmation testing on 20th April 2017. 3rd Round Testing on 25th May 2017 after replacing the fixtures.	Deficiencies Corrected. 3rd Round Testing Done. Results below Screening Level. Wood shop fixture being closed for students by school. Official letter in database.	High PCA Results	Fisture Capped Off!	X
48	Higley USD	Higley Traditional Academy	Confirmation Test Results >15 PPB				Y	Bldg 400 classroom sink RM 420	Initial Test@22.6			Signage	X
49	Isaac Elementary District	Alta Butler Elementary School	Confirmation Test Results >15 PPB			Done. 1 Sink Faucet & 1 Filter	Y	Building H bubbler sinks(2)	confirm. tests>15ppb	PO's have been issued and the Corrective Actions for PCA have been complete	High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
50	Isaac Elementary District	J B Sutton Elementary School	Confirmation Test Results >15 PPB			Done. 4 Sink Faucets, 4 Filters and 1 Drinking Fountain	Y	Bldg F & A sinks	Confirmation tests @ 310&43, 47&95&26, 140 PPB	PO's have been issued and the Corrective Actions for PCA have been complete	Low PCA Results		X
51	Isaac Elementary District	Joseph Zito Elementary School	Confirmation Test Results >15 PPB			Done. 1 Sink Faucet, 2 Filters and 1 Drinking Fountain	Y	Bldg C fountain & Bldg E sink	Confirmation tests @ 16&18&20, 1200&57 PPB	PO's have been issued and the Corrective Actions for PCA have been complete	Low PCA Results		X
52	Isaac Elementary District	PT Coe Elementary School	Confirmation Test Results >15 PPB			Done. 5 sink faucets, 3 filters and 1 bubbler	Y	Bldg O fountain, room 48 & bldg L sink, room 39	Confirmation tests @ 26&19, 46 PPB	PO's have been issued and the Corrective Actions for PCA have been complete	Low PCA Results		X
53	Kayenta USD	Kayenta Primary School	Confirmation Test Results >15 PPB				Y	Sink in front office/counselor	Sampling to be done soon waiting on test results		High PCA Results	Pursing corrective actions	X
54	Kyrene Elementary District	C.I. Waggoner ES	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain.	Y	Kitchen faucets & ftn	BRG Approved. Waiting for Corrective Actions to get completed	BRG Approved for the Drinking Fountain in the Multi-Purpose Room	High PCA Results	Signages To Be Put as a part of Permanent Corrective Action! Thus, Project Closeout To Be Completed!	X
55	Kyrene Elementary District	Kyrene Akimel A-al Middle School	Confirmation Test Results >15 PPB				Y		Signages to be a part of Corrective Action. Jack sent the Confirmation Email regarding this decision.		Signages Posted		X
56	Lake Havasu UD	Smoketree ES	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain.	Y	Bldg 1002 between rms1&2 outside ftn	Ready for the 3rd Round Testing	1 Drinking Fountain	Low PCA Results		X
57	Mammoth-San Manuel Unified District	San Manuel High School	Confirmation Test Results >15 PPB			Done. 2 H/L DFs.	Y	Baseball field, press box, Bldg D	BRG Approved!	The outside hose bib is capped off. The hot water heater in the central plant will have a perminant warning sign installed.	Low PCA Results		X
58	Marana Unified School District	Butterfield ES	Confirmation Test Results >15 PPB			Done. Sink with a Bubbler	Y	Bldg. N-1013 sink	In Progress		Low PCA Results		X
59	Marana Unified School District	Mountain View High School	Confirmation Test Results >15 PPB			Contacted. TBC.	Y	Café faucet & bookstore Elkay ftn			Low PCA Results		X
60	Marana Unified School District	Tortolita Middle School	Confirmation Test Results >15 PPB			Done. 1 Sink	Y	Gym Concession sink	Sink in the Concession Room in the Gym Area to be Capped Off!		Capped Off		X
61	Mesa Unified School District	Adams ES	Confirmation Test Results >15 PPB			Contacted. 1 Sink/DF	Y	Confirmation tests > 15 PPB from sink/df from room 53	Bldg 1013 sample is from a non-drinking water source so confirm. Test is not required		High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
62	Mesa Unified School District	Crismon ES	Confirmation Test Results >15 PPB				Y	Bldgs 1004-1007 taps(3), DF's(2)			High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
63	Mesa Unified School District	Eisenhower ES	Confirmation Test Results >15 PPB			Contacted. 1 Sink Fountain.	Y		Done	Done	High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
64	Mesa Unified School District	Emerson ES	Confirmation Test Results >15 PPB			TBC	Y	Bldg's 1009&1014 ftns/sinks		Done	High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
65	Mesa Unified School District	Entz ES	Confirmation Test Results >15 PPB			Contacted. 3 Tap/Sink	Y	Bldgs 1002 rm A1&A5 & 1006 rm C2 taps	done		Low PCA Results		X
66	Mesa Unified School District	Field ES	Confirmation Test Results >15 PPB			Contacted. 2 Drinking Fountain and 1 Sink.	Y	Bldgs 1002,1012,1013(P-13),1013 DF&sinks		Plumbing corrective actions	High PCA Results	Building 1012 P-8 and Building 1013 P14 Drinking fountain have low 4th round test results. Building 1013 P14 Sink still needs to be retested for 4th round	X
67	Mesa Unified School District	Franklin at Alma ES	Confirmation Test Results >15 PPB			Contacted. 3 Bubblers.	Y	Bldg D&T		Plumbing corrective actions	High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
68	Mesa Unified School District	Franklin South ES	Confirmation Test Results >15 PPB			Contacted. 5 Drinking Fountain and 3 Faucets.	Y	Bldg 1006-1011 drinking ftns		Plumbing corrective actions	Low PCA results for room 17. High PCA Test results for room 9-16 and 18.	Low 4th round test results for room 9, 11, 14, 16, & 18. Still need results for room 10, 12, 13, 15	X
69	Mesa Unified School District	Fremont Jr HS	Confirmation Test Results >15 PPB			Contacted. 1 Drinking Fountain.	Y	Bldg 1005 1 drinking fountain rm 81		BRG/EA Approved	High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X

70	Mesa Unified School District	Hale ES	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain/Sink.	Y	Bldg 1010 drinking water/sink	done		Low PCA Results		X
71	Mesa Unified School District	Hawthorne ES	Confirmation Test Results >15 PPB			Initial test@21ppb	Y	1006 D.F.	Bldg 1015 sample is from a non-drinking water source so confirm. Test is not required	Done	High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
72	Mesa Unified School District	Hermosa Vista ES	Confirmation Test Results >15 PPB			Done. 2 Sink Taps.	Y	Bldg 1009 portable 40			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
73	Mesa Unified School District	Holmes ES	Confirmation Test Results >15 PPB			Done. 6 Sinks.	Y	Bldgs 1001a,1002C,1008,1014 sinks(4) & spigot			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
74	Mesa Unified School District	Irving ES	Confirmation Test Results >15 PPB			Contacted. 2 Sinks.	Y	Bldgs 1007 &1008 sinks			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
75	Mesa Unified School District	Jefferson Elementary School	Confirmation Test Results >15 PPB			Contacted. 3 Drinking Fountains.	Y	Portable 1009(3) & 1010(2) fountains in rooms 32,31,33			High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
76	Mesa Unified School District	Jordan Center for Early Education	Confirmation Test Results >15 PPB			Done. 4 Sinks.	Y	4 Fixtures > 15 PPB are from sink; Bldg 1006 & 1008	Both Bldg 1006 and 1008 need 4th round testing		High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
77	Mesa Unified School District	Keller ES	Confirmation Test Results >15 PPB			Done. 2 Drinking Fountains.	Y	Bldg 1006 sink/ftn			High PCA Results	Low 4th Round Test Results	X
78	Mesa Unified School District	Lehi ES	Confirmation Test Results >15 PPB				Y	Bldgs 1003-1005, 1007-1008 taps & ftns	Bldg 1004 and 1005 got cleared off. Bldg 1003, 1007 and 1008 needs 4th round testing.		High PCA Results	Low 4th Round Test Results for H3, H1, and F1. Project Closeout To Be Completed	X
79	Mesa Unified School District	Lincoln ES	Confirmation Test Results >15 PPB				Y	Bldg 1003 Media Ctr sink			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
80	Mesa Unified School District	Lindbergh ES	Confirmation Test Results >15 PPB			Done.	Y	Bldgs 1008 rm 313 & 1010(2) rm 704&703 ftns	done		Low PCA Results		X
81	Mesa Unified School District	Longfellow ES	Confirmation Test Results >15 PPB				Y	Bldgs 1013(2), 1014(1) ftn/sink			High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
82	Mesa Unified School District	Lowell ES	Confirmation Test Results >15 PPB			work being done in house	Y	Bldg 1014 ftn, Bldg 1015 ftn(2),			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
83	Mesa Unified School District	McKellips Learning Center	Confirmation Test Results >15 PPB			Per Joe, not being used for Students but for IT Services and Transportation.	Y	Bldgs 1003 sink(1) & 1008 ftns(2)	Joe to send an email to confirm the adjacent statement.	Not a school		Not a school	X
84	Mesa Unified School District	Mesa HS	Confirmation Test Results >15 PPB				Y	Bldg 1009 rm 505 & 506 sink			High PCA Results	Signage	X
85	Mesa Unified School District	Mendoza ES	Confirmation Test Results >15 PPB				Y	Bldg 1011 sink&1015 drinking ftn		Bldg 1015 got cleared off in the PCA Testing!	High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
86	Mesa Unified School District	Mountain View High School	Confirmation Test Results >15 PPB			Done. 4 Drinking Fountains.	Y	Bldg 1005 Boys locker room ftn	BRG/EA Approved		Low PCA Results		X
87	Mesa Unified School District	Patterson Elementary School	Confirmation Test Results >15 PPB			Done. 1 Sink.	Y	Bldg 1004 room 40 sink			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
88	Mesa Unified School District	Redbird ES	Confirmation Test Results >15 PPB				Y	Bldgs 1011&1012 faucets	Bldg 1011 Cleared Off in PCA Testing. Bldg 1012 still needs 4th round testing		High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
89	Mesa Unified School District	Rhodes Jr HS	Confirmation Test Results >15 PPB				Y	Bldgs 1008(3),1009(4) taps			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
90	Mesa Unified School District	Robson ES	Confirmation Test Results >15 PPB			Done. 2 Drinking Water/Sink.	Y	Bldg 1005 rooms 31&29 sinks			High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
91	Mesa Unified School District	Salk ES	Confirmation Test Results >15 PPB			Done. 2 Drinking Fountain.	Y	Bldg 1008 fountains(2)	Bldg 1014 sink	Low PCA Results for fixture in FC-6 and FC-5 in Bldg 1008.	Low PCA Results		X
92	Mesa Unified School District	Sharp	Confirmation Test Results >15 PPB				Y	Bldgs 1012 faucet,1014 sink, 1016 ftn	Bldg 1012, 1014 and 1016 need 4th round testing		High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
93	Mesa Unified School District	Sirrene ES	Confirmation Test Results >15 PPB			Done. 5 Sink/Drinking Fountain.	Y	Bldg. 1010, 1009, 1011	P-7 is in Bldg 1009; P-9 and 10 in Bldg 1010; P-11 and 12 in Bldg 1011; All need 4th round testing		High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
94	Mesa Unified School District	Sousa ES	Confirmation Test Results >15 PPB			Done. 2 Drinking Fountains.	Y	Bldg 1008 drinking fountains(4)	Done		High PCA Results	Low 4th Round Test Results! Project Closeout To Be Completed!	X
95	Mesa Unified School District	Stevenson ES	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain by Sink.	Y	Bldg 1002 Media Center water fountain	Confirmation test@27 ppb		Low PCA Results		X
96	Mesa Unified School District	Summit-Hendrix Jr HS	Confirmation Test Results >15 PPB			Bldg 1005 confirm Tests@550, 27,73,280ppb	Y	Bldg 1005 drinking ftns is forwarded to further testing; Bldg 1006 Drinking Fountain termed as a Non-Drinking Water Source by ADEQ	Bldg 1005 needs 4th round testing		High PCA Results	Low 4th Round Test Results. Project Closeout To Be Completed	X
97	Mesa Unified School District	Washington ES	Confirmation Test Results >15 PPB			Done. 6 Sinks.	Y	Bldgs 1008, 1012, & 1013 sinks / dfs(6)			High PCA Results	F-1, F-3, F-4 Low 4th round test results. F-2, H-1, H-2	X
98	Mesa Unified School District	Webster ES	Confirmation Test Results >15 PPB			Done. 2 Drinking Fountains.	Y	Bldgs 1003,1009,1012 ftns(2)&sinks(2)			High PCA Results	Low 4th Round Test Results. Project Closeout To Be Completed	X

99	Mesa Unified School District	Westwood HS	Confirmation Test Results >15 PPB		Done. 2 Sinks.	Y	Bldgs 1007 & 1031 sinks		High PCA Results	Low 4th Round Test Results. Project Closeout To Be Completed	X	
100	Mesa Unified School District	Whitman ES	Confirmation Test Results >15 PPB		Done. 2 Drinking Fountains.	Y	Bldg 1007 room 45 ftn	done	Low PCA Results		X	
101	Miami Unified District	Lee Kornegay Middle School	Complete		Signs Posted. No further action required.	N	C&D Bldg, Baseball&PressBox	sample was from a non drinking water source	Signages Posted		X	
102	Miami Unified District	Miami High School	Complete		Signs Posted. No further action required.	N	Library First draw@25, confirm. flush@3.2&confirm. day2@6.9; Auditorium Ftn<15ppm	sample was from a non drinking water source	Signages Posted		X	
103	Murphy Elementary District	Jack L. Kuban School	Confirmation Test Results >15 PPB		Done. 3 Sinks and 5 Drinking Fountains.	Y	Bldg B sink& DF. Bldg A Sink. Bldg D sink & four DF	Confirmation tests @ 48&74, 34, 45,230& 66, 16, 16, 20, 20, 25	Pursing Corrective Actions		X	
104	Nogales Unified District	Nogales High School	Confirmation Test Results >15 PPB		Done. 1 Drinking Fountain.	Y		PCA Results<15ppb	Low PCA Results		X	
105	Osborn School District	Longviews ES	Confirmation Test Results >15 PPB		Done. 1 Mixing-Valve	Y	Bldg 1008 sink	Sampling is done for PCA testing. Waiting for test results	Done in house	Low PCA Results	X	
106	Paradise Valley Unified District	Arrowhead ES	Confirmation Test Results >15 PPB		Done. 1 Drinking Fountain.	Y	Lounge fountains(2)	High PCA Results	High PCA Results	Low 4th Round Test Results! Thus, Project Closeout To Be Completed!	X	
107	Paradise Valley Unified District	Cholla Complex	Confirmation Test Results >15 PPB		TBC	Y	Main Bldg fountain& taps(2)		Low PCA Results		X	
108	Paradise Valley Unified District	Foothills ES	Confirmation Test Results >15 PPB		Done. 1 Faucet.	Y	Multi Purpose Bldg - Kitchen - Tap	Confirmation test @ 27	Low PCA Results		X	
109	Paradise Valley Unified District	Greenway MS	Confirmation Test Results >15 PPB		Done. 10 Taps and 1 Faucet.	Y	Bldg 500 Center & 500N taps		Low PCA Results		X	
110	Paradise Valley Unified District	Shadow Mountain HS	Confirmation Test Results >15 PPB		Done. 4 Drinking Fountains.	Y	Bldg 500 Gym fountain	Initial test@15.8	High PCA Results	Low 4th Round Test Results. Project Closeout To Be Completed	X	
111	Paradise Valley Unified District	Vista Verde MS	Confirmation Test Results >15 PPB		Done. 1 Faucet.	Y	Bldg G faucet		Signages Posted		X	
112	Payson Unified District	Payson High School	Confirmation Test Results >15 PPB		Done. 1 Sink.	Y	Dome concession sink	Quad & Auditorium samples taken were not from drinking water source. Sampling to be done shortly.	Low PCA Results		X	
113	Peoria USD	Sun Valley HS	Confirmation Test Results >15 PPB		Done. 1 Drinking Fountain.	Y	Bldg 1018 fountain&1021 sink	initial test@106&25	Done	Low PCA Results	X	
114	Phoenix Elementary District	Augustus H Shaw Montessori	Confirmation Test Results >15 PPB		Done. Sink with a Bubbler	Y	N.E. Bldg Rm No. 446 DF		Done Inhouse!	Low PCA Results	X	
115	Phoenix Elementary District	Garfield Elementary School	Confirmation Test Results >15 PPB		Done. 2 Sinks.	Y	Workroom 111 Sink & Restroom 235 Sink	Signages to be posted by taking permission from Superintendent as they are not drinking water sources.	Done Inhouse!		X	
116	Phoenix Elementary District	Paul Dunbar Lawrence School	Confirmation Test Results >15 PPB		Done. 1 High-Low Drinking Fountain!	Y	Gym High and Low Drinking Fountain	initial test@20.4	Done Inhouse!	Low PCA Results	X	
117	Phoenix UHSD	Bostrom Alternative School	Confirmation Test Results >15 PPB		Done. 1 Sink.	Y	Bldg 200 Math sink, 1014 sink,1015 sink&ftn, 1024 sink	BRG Approved through AZ-JOC (RKS)	Corrective action done - waiting for test results		X	
118	Phoenix UHSD	Carl Hayden HS	Confirmation Test Results >15 PPB		Done. 2 Taps and 6 Drinking Fountains.	Y	Bldg's 900,1200&400 taps&ftns	BRG Approved through AZ-JOC (RKS)	Corrective action done - waiting for test results		X	
119	Pine Strawberry Elementary District	Pine Strawberry Elementary School	Confirmation Test Results >15 PPB		Done. 1 Ladies Restroom Sink and 1 LDS Museum Kitchen Sink	Y	Ladies Restroom faucet & LDS Museum sink	CONFIRM TESTS>15ppb	Corrections Done In-House!	Ladies Restroom Faucet came low in PCA Testing but LDS Museum Sink came high which has to be abandoned by the School District!	X	
120	Ray Unified District	Ray Elementary School	Confirmation Test Results >15 PPB		Done. 1 Football Concession Tap.	Y	Football concession sink tap	confirm.test@27ppb; District Insurance Company advised that signage is acceptable	High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X	
121	Roosevelt Elementary District	Amy Houston Academy	Confirmation Test Results >15 PPB		Done. 1 Sink with a Bubbler.	Y	1 Drinking Fountain		1 Drinking Fountain (Inhouse)	High PCA Results	Low 4th Round Results. Project Closeout To Be Completed	X
122	Roosevelt Elementary District	Cloves C. Campbell ES	Confirmation Test Results >15 PPB		Done. 1 Sink with a Bubbler.	Y	Bldg 1001-1 drinking fountain	Done!		Low PCA Results	X	
123	Roosevelt Elementary District	Rose Linda ES (Irene Lopez ES)	Confirmation Test Results >15 PPB		Done. 1 Standalone Drinking Fountain.	Y	Office sink & faucet	Done!		Low PCA Results	X	
124	Round Valley Unified District	Round Valley Primary School	Confirmation Test Results >15 PPB		Done. Sinks	Y					X	
125	Sacaton ESD	Sacaton MS	Confirmation Test Results >15 PPB		Done. 2 Sinks.	Y	Bldgs 1003&1010		2 Sinks Done In-house!	Low PCA Results	X	
126	Scottsdale Unified School District	Apache Site	Confirmation Test Results >15 PPB			Y	Bldg B outside DF(2) & sinks(8)	confirm.tests>15ppb	Pursuing corrective actions		X	
127	Scottsdale Unified School District	Chaparral HS	Confirmation Test Results >15 PPB		Done. 1 Sink.	Y	Bldg H Dressing Room Dirty Sink	Confirmation Test@114 PPB	Pursuing corrective actions		X	
128	Scottsdale Unified School District	Cherokee ES	Confirmation Test Results >15 PPB		Done. 1 Drinking Fountain and 1 Sink.	Y	Bldg D Room D9 DF	Confirmation Test @ 94 and 18 PPB	Pursuing corrective actions		X	
129	Scottsdale Unified School District	Cheyenne	Confirmation Test Results >15 PPB			Y			Pursuing corrective actions		X	
130	Scottsdale Unified School District	Desert Mountain High School	Confirmation Test Results >15 PPB		Done. 1 Sink.	Y	Bldg 9000 Sink		Pursuing corrective actions	Low PCA Results	X	
131	Scottsdale Unified School District	Hohokam	Confirmation Test Results >15 PPB		Done. 1 Sink.	Y	Bldg A Room No. 12 Sink 1-G		Pursuing corrective actions	Low PCA Results	X	
132	Scottsdale Unified School District	Hopi Elementary	Confirmation Test Results >15 PPB		Done. 2 Sink Faucets.	Y	Music sink & Bldg C sink	initial test@31&25	Pursuing corrective actions		X	
133	Scottsdale Unified School District	Kiva Elementary School	Confirmation Test Results >15 PPB		Done. 1 Drinking Fountain and 1 Sink Faucet.	Y	Bldg D	Confirmation Test@ 110,46 and 27.	Pursuing corrective actions	Low PCA Results	X	
134	Scottsdale Unified School District	Navajo ES	Confirmation Test Results >15 PPB		Done. 1 Sink.	Y	Room 51		Pursuing corrective actions	Low PCA Results	X	
135	Scottsdale Unified School District	Pima	Confirmation Test Results >15 PPB		Done. 2 Sinks.	Y	Room 23		Pursuing corrective actions		X	
136	Scottsdale Unified School District	Tonalea k-8 (formerly Supai MS)	Confirmation Test Results >15 PPB		Done. 5 Sinks.	Y	Room 2, 6,7.		Pursuing corrective actions		X	

137	Sierra Vista USD	Joyce Clark MS	Confirmation Test Results >15 PPB							Done Inhouse	Capped Off		X
138	Sunnyside Unified School District	Challenger Middle School	Confirmation Test Results >15 PPB				Y		Hosebib. Fernando sent an email confirmation regarding capping it off	Hosebib Capped Off!	Fixture Capped Off		X
139	Sunnyside Unified School District	Los Ninos ES	Confirmation Test Results >15 PPB			Done. 15 Sinks Scrapped Off and 8 Drinking Fountains Installed by the District!	Y	Sahuaro Hall bubblers		Sinks Removed from the Classrooms and 8 Drinking Fountains installed in the Hallway! 1 tested High in the PCA Testing and thus, shifted to Further Investigations for 4th Round Testing!	High PCA Results	The Fixture Capped Off. Project Closeout To Be Completed	X
140	Sunnyside Unified School District	Los Ranchitos School	Confirmation Test Results >15 PPB			Done. 7 Sinks Scrapped Off and New Drinking Fountains To Be Installed by the District!	Y	200 Wing, 7 DF		We need test reults			X
141	Tempe Elementary District	Connolly Middle School	Confirmation Test Results >15 PPB			Done.	Y				Low PCA Results		X
142	Tempe Elementary District	Evans ES	Confirmation Test Results >15 PPB			Done.	Y	Bldgs1001 & 1006 sinks			Low PCA Results		X
143	Tempe Elementary District	Fees Middle School	Confirmation Test Results >15 PPB			Done.	Y	Bldg 1005 Drinking Fountain & Bldg 1002 sink	Initial Test@ 25 and 16 PPB		Low PCA Results		X
144	Tempe Elementary District	Nevitt Elementary School				Done.	Y	Bldg 1009 tap/sinks	Initial Test@17ppb		Low PCA Results		X
145	Tempe Elementary District	Tempe Academy of International Studies	Confirmation Test Results >15 PPB			Done.	Y	Bldgs 1006(4),1009(3)&1011(4) sinks	need 3rd round testing		Low PCA Results		X
146	Tempe Union High School District	Marcos de Niza High School	Confirmation Test Results >15 PPB			Done. 3 Faucets.	Y	Bldgs 300(2) and 300T(1)	Confirm. tests>15ppb	Done Inhouse!	Low PCA Results		X
147	Tempe Union High School District	McClintock High School	Confirmation Test Results >15 PPB			Done. 3 Faucets.	Y	Bldgs 400(2) and 1400B(1)		Done Inhouse!	Low PCA Results		X
148	Tolleson Union High School District	Tolleson Union High School	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain and 1 Sink	Y	Library Drinking Fountain, Cafeteria and Restroom Sink	District Working on Purchasing a New Filter to install in the newly replaced Drinking Fountain!	Done in house	Low PCA Results		X
149	Tombstone Unified District	Walter J Meyer School	Confirmation Test Results >15 PPB			Done. 1 Sink (Mixing Valve)	Y	Sink in Nurse's Office	BRG/EA Approved by AZ-JOC		Low PCA Results		X
150	Tucson Unified School District	Maxwell Middle School	Confirmation Test Results >15 PPB				Y	PE boys locker DF storage rm			Low PCA Results		X
151	Tucson Unified School District	Palo Verde Magnet High School	Confirmation Test Results >15 PPB				Y	Shop sink & drinkingftn			Signages Posted		X
152	Tucson Unified School District	Rincon-University High School	Confirmation Test Results >15 PPB				Y	LIBRARY drinking fountain			Low PCA Results		X
153	Tucson Unified School District	Sabino High School	Confirmation Test Results >15 PPB				Y	Tech Bldg. fountain			Low PCA Results		X
154	Tucson Unified School District	Sahuaro High School	Confirmation Test Results >15 PPB				Y	Nurses office sink			Low PCA Results		X
155	Washington Elementary District	Desert View ES	Confirmation Test Results >15 PPB			Done.	Y	Bldg F1006 room 402 sink		Fixtures Removed	Fixture Removed		X
156	Washington Elementary District	John Jacobs ES	Confirmation Test Results >15 PPB			Done	Y	Bldg C1003 Library Room sink		Done	Low PCA Results		X
157	Washington Elementary District	Sunset ES	Confirmation Test Results >15 PPB			Done.	Y	BldgC1003 sink rooms(3)		Done	Low PCA Results		X
158	Wickenburg Unified District	Vulture Peak School	Confirmation Test Results >15 PPB				Y	Bldg 1003 sink; Sink in the Shop; No students or Teachers allowed in that area; Removed and replaced the fixture before Confirmation Testing	Don't need any 3rd round tests	Signages to be a part of Corrective Action! Yet to receive the Confirmation Mail from the District!	Signages Posted		X
159	Yuma Elementary District	Gwyneth Ham Elementary School	Complete				Y				Signages Posted		X
160	Yuma Union High School District	Yuma High School	Confirmation Test Results >15 PPB			Done. 1 Drinking Fountain.	Y	1 drinking fountain	Greenhouse sample taken from non-drinking water source. DF still need in 2nd floor hallway. BRG Submitted; EA Approved	1 Drinking Fountain. School forwarded to ADEQ for 3rd Round Testing.	Low PCA Results		X